

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE.

No. 101/2026Date: 24/04/2026

It is certified that an inspection team headed by Dr. Bodha madam,
medical officer. from Government
 Health Department Late Murlidhar Pandurang Laigude Hoapital Dhayari (PMC Hospital)
 Pune Maharashtra 411068. Inspected the Pawar Public School, Nanded City, Sinhagad
 Road, Pune, Maharashtra 411041 on 24/4/2026 and found that the Pawar Public
 School has safe drinking water facilities for the students and members of staff of the
 institution and is maintaining the hygienic sanitation condition in the school building & the
 campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 years

Signature with Seal :  24/4/26

Name : Dr. Asmita Bodhe

Designation : medical officer.

To
 Pawar Public School,
 Nanded City, Sinhagad Road,
 Pune Maharashtra 411041




 Dr. Anjali Gurjar
 Principal

PAWAR PUBLIC SCHOOL NANDED CITY
 Sinhagad Road, Pune 411041

स्व. मुरलीधर पांडुरंग लायगुडे
 जनसुखवर्धनी केंद्र, पुणे म.न.पा.




GOVT. OF MAHARASHTRA

DEPUTY DIRECTOR, HEALTH SERVICES
STATE PUBLIC HEALTH LABORATORY, PUNE.
Near St. Mary School And Church, Pune 411001

Telephone - Office :- (020) 263300225 Ext. 223

Email : statehealthlab@gmail.com



HEALTH SERVICES

NO.:- SPHL PUNE /Desk -79 / 08 / 2026. DATE :- 07/04/2026.



TC-11706

Report on Chemical Analysis of Water

Sent by :- Pawar Public Schools, Nanded City, Pune-41.

With Ref. letter No :-

Dated :- 06/03/2026

Date of Collection :- ----

Date of Receipt :- 06-03-2026

Date of Examination :- 09/ 03 / 2026 Onwards

(All the Analytical Results are in mg. / Lit. except pH , Turbidity .

Parameters under Scope

SR. NO	TEST PARAMETER	S.No -1 (P-143) Filter Water	Test Method	BIS Specifications 10500 : 2012 Normal Values	
				Desirable limit	Permissible limit
1	pH Value	7.86	FSSAI, Manual of methods Of Analysis of Water With 2016.	6.5 to 8.5	No relaxation
2	Chloride (as Cl)	8.77	FSSAI, Manual of methods Of Analysis of Water With 2016.	250	1000
3	Total Hardness (as CaCO_3)	40.36	FSSAI, Manual of methods Of Analysis of Water With 2016.	200	600
4	Alkalinity (as CaCO_3)	27.93	FSSAI, Manual of methods Of Analysis of Water With 2016.	200	600



Dr. Anjali Gurjar
Principal

PAWAR PUBLIC SCHOOL NANDED CITY
Sinhagad Road, Pune 411041

Parameters not under Scope

SR. NO	TEST PARAMETER	S.No -1 (P-143) Filter Water	Test Method	BIS Specifications 10500 : 2012 Normal Values	
				Desirable limit	Permissible limit
1	Physical Appearance	Clear	---	---	---
2	Odour	agreeable	---	agreeable	agreeable
3	Turbidity (as N.T.U.)	0.65	FSSAI, Manual of methods Of Analysis of Water With 2016.	1.0	5.0
4	Nitrates (as No ₃)	ND	A.P.H.A. 24 th Edition	45	No relaxation
5	Total Dissolved Solids	55.0	FSSAI, Manual of methods Of Analysis of Water With 2016.	500	2000
6	Iron (as Fe)	ND	FSSAI, Manual of methods Of Analysis of Water With 2016.	1.0	No relaxation
7	Fluoride (as F)	ND	FSSAI, Manual of methods Of Analysis of Water With 2016.	1.0	1.5

- ND :- Not detected.
- This report is restricted only for the sample /s submitted to this laboratory.
- It is presumed that the representative sample from the source is sent for analysis.
- This Sample /s is /are not collected by this laboratory.

Remark :- S.No. -1 is chemically fit for drinking purpose on the basis of analysed parameters Only.
However, this water source can be used for drinking purpose only after proper treatment, disinfection & ascertaining its bacteriological quality frequently or regularly.

Forwarded With Compliments To :- Pawar Public Schools, Nanded City, Pune-41.

Fees	600 /-
Receipt No.	7763123
Date	06/03/2026


Government Analyst,
State Public Health Laboratory, Pune.




Dr. Anjali Gurjar
Principal

PAWAR PUBLIC SCHOOL NANDED CITY
Sinhagad Road, Pune 411001

		 STATE PUBLIC HEALTH LABORATORY, PUNE			
Dy Director tele No. 26330509 (P) Office Tele No. 26330225 (O)		Cantonment water works campus, Near Saint Mary Church, Staveley road, Pulgate, Pune-411 001 (MH) INDIA Email ID : sphlmis@gmail.com , statehealthlab@gmail.com website : arogya.maharashtra.gov.in			
HEALTH SERVICES:		No.SPHLPUNE/Desk-80/Bact.Section/water analysis report/ 2970 / 2026 Date : 09/03 2026			

Bacteriological Report of water Sample

Sender's Name	Pawar Public School, Nanded City, Pune - 41
Sender's letter No. & date	-- / 06-03-2026
Lab. Reference No.	40 / 192
Date of sample collection	06-03-2026
Date of sample received	06-03-2026
Analysis start date	06-03-2026

	Sample Description	Bacteriological Analysis result			
		Most Probable Number of bacteria found per 100 ml of Water Sample			
		Coliforms	Thermotolerant Coliforms	<u>E.coli</u>	Conclusion
1.	Pawar Public School, Nanded City, Pune - Filter	0	-	-	Potable

Remark: If water sample found non-potable, it can be used for drinking purposes after proper treatment and ascertaining its bacteriological quality for potability by retesting.

Note: Above sample/samples is/are not collected by this laboratory and result is/are as per submitted sample/samples.

Fee Rs. : 340/-


Receipt No. : 7763129

Date : 06-03-2026




Dr. Anjali Gurjar
Principal

PAWAR PUBLIC SCHOOL NANDED CITY
Sinhagad Road, Pune 411041


Chief Bacteriologist
State Public Health Laboratory, Pune